



Reg. No. 041/P-007

NOTIFIED BODY No. 1396
Osloboditeľov 282, 059 35 Batizovce, Slovakia
tel. +421 52 7752298 fax. +421 52 7881412 http://www.fires.sk



Certificate of constancy of performance

1396-CPR-0021

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

AUTOMATIC SMOKE BARRIERS (ASB2, ABS 4) mcr PROSMOKE CE AND mcr PROSMOKE CE 1

designed to control the movement of fire effluent within construction works by forming a barrier. Product is used on conditions defined in Initial type testing report No. C1396/08/0015/5004/SC (issued by FIRES, s.r.o., NB 1396 on 23. 07. 2008) amended by an actual report of continuous surveillance. Product is

placed on the market under the name or trade mark of

**“MERCOR” S.A.
ul. Grzegorza z Sanoka 2, 80-408 Gdańsk, Poland**

and produced in the manufacturing plant

**“MERCOR“ S.A.
Zakład Produkcyjny Systemów Oddymiania i Wentylacji,
ul. Kwarcowa 3A, Ciepłowo, 83 031 Łęgowo, Poland.**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard


EN 12101-1: 2005, EN 12101-1:2005/A1: 2006

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 23. 07. 2008 and will remain valid as long as neither the harmonized standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Batizovce, 11. 11. 2021




Ing. Henrieta Lapková
Head of Product Certification Body

131477

FIRES 136a/C-31/01/2017-E