



Reg. No. 041/P-007

NOTIFIED BODY 1396
Osloboditeľov 282, 059 35 Batizovce, Slovakia
Tel.+421 52 285 1611, www.fires.sk



Certificate of constancy of performance

1396-CPR-0133

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Automatic smoke barrier (ASB) mcr PROSMOKE ONE C

active smoke barrier, type ASB2 and ASB4, is designed as a part of smoke and heat control systems for creation of smoke reservoirs inside the building, for control of movement of smoke and heat inside the building and for increase of efficiency of natural or powered smoke and heat exhaust ventilators. Product used on conditions specified in Assessment and verification of constancy of performance Nr.C1396/18/0002/4004 (published by FIRES, s.r.o., NB 1396 on 13.03.2018) amended by an actual report of continuous surveillance is

placed on the market under the name or trade mark of

"MERCOR" S.A.

ul. Grzegorza z Sanoka 2, 80 – 408 Gdańsk, Poland

and produced in the manufacturing plant

"MERCOR" S.A.

ul. Kwarцова 3A, 83-031 Ciepłowo k. Gdańska, Poland.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard


EN 12101-1:2005 and EN 12101-1:2005/A1:2006

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 13. 03. 2018 and will remain valid as long as neither the harmonized standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Batizovce 13. 04. 2021



Ing. Henrieta Lapková
Head of Product Certification Body

124974

FIRES 136a/C-31/01/2017-E