

OPERATION AND MAINTENANCE MANUAL

Long-range smoke exhaust fan

mcr FEN C F400/F300

mcr FEN C/BO

mcr FEN EC



Version: 25.05.26.1

FIRE VENTILATION SYSTEMS

TABLE OF CONTENTS:

1. FOREWORD	3
2. MANUFACTURER'S DISCLAIMER	3
3. SUBJECT OF DOCUMENTATION	3
4. INTENDED USE	4
4.1. Application	4
4.2. Fire resistance	4
4.3. Versions	5
5. DESIGNATION	4
6. DESIGN AND OPERATING PRINCIPLE	5
6.1. Design	5
6.2. Operation	5
6.3. Dimensions and technical data	5
7. ASSEMBLY	7
7.1. Pre-assembly inspection	7
7.2. Location and assembly	7
7.3. Electrical connections	7
7.4. Start-up	8
8. TRANSPORT AND STORAGE CONDITIONS	8
9. OHS MANUAL	8
10. MAINTENANCE AND SERVICING	9
11. WARRANTY TERMS & CONDITIONS	9
FAN MEASUREMENT REPORT	11

CAUTION:



Risk of injury from sharp edges, sharp corners and thin sheet metal elements.
Be careful when handling and working with the device.
Wear protective gloves, safety shoes and a helmet.

Risk of electric shock. Do not touch live parts. Only employees with the appropriate qualifications and certificates may perform electrical connections.
Disconnect the power supply before starting work on electrical equipment.

NOTE

**All previous issues of this Technical Manual expire on the date of issue hereof.
This O&MM does not apply to fans manufactured before the date of its issue.**

1. FOREWORD

This O&MM is intended for users of mcr FEN C long-range fans. Its purpose is to provide guidance on the application, construction, commissioning and operation of the above-mentioned product.



Read this document thoroughly before installing this device at its operating site and its start-up.



In the event of faulty operation or defects, please contact the manufacturer or its authorised representative.



Due to the constant improvement of our products, we reserve the right to make design changes that increase the performance and safety of the device.

The design of the fans meets the essential requirements of the PN-EN 12101-3:2015 standard. It also meets the requirements of the current state of technology and ensures safety and health protection.

2. MANUFACTURER'S DISCLAIMER

- The manufacturer shall not be liable for any consequences of misuse of the device.
- Do not install additional elements on the device that are not its component or accessory.
- Any unauthorised alterations or modifications to the device are prohibited.
- The device housing must be protected from mechanical damage.
- Before installing the device, check the load-bearing capacity of the structural elements to which the device will be attached. Unreliable attachment may result in damage or destruction of the device, and may also pose a risk to people nearby.
- This fan is not intended for forcing air with viscous pollutants that may settle on the device, and especially on its rotor.
- This fan is not intended for forcing air with corrosive pollutants that may be detrimental to the device.
- During use, the maximum speed of the rotor should not be higher than the rated speed.
- The manufacturer shall not be liable for any injuries, trauma or other bodily harm caused by misuse of this device.

3. SUBJECT OF DOCUMENTATION

The subject of this O&MM is:

- mcr FEN C F400 long-range smoke exhaust fan
- mcr FEN C F300 long-range smoke exhaust fan
- mcr FEN C/BO long-range fan without fire resistance
- mcr FEN EC long-range fan without fire resistance

4. INTENDED USE

4.1. Application

mcr FEN long-range fans are designed to remove smoke and heat generated in rooms during a fire (FEN C version). They facilitate evacuation of persons from the area on fire, protect the building structure and its furnishing from high temperature, facilitate firefighting, and inhibit spreading of fire to adjacent fire zones. The fans can also be made in a version without fire resistance (mcr FEN C/BO version) and in a version without fire resistance on a 230V AC voltage (FEN EC version).

The fans are installed inside the buildings, in a horizontal position on appropriate supports.



The fan in the general ventilation system can operate in the ambient temperature range from -20 °C to +40 °C.

It can force dry air with dust content no greater than 0.3 g/m³.



This fan is not intended for forcing air with viscous pollutants that may settle on the device, and especially on its rotor.



This fan is not intended for forcing air with corrosive pollutants that may be detrimental to the device.



During use, the maximum speed of the rotor should not be higher than the rated speed.



A fan that has been operating in extreme fire conditions is not suitable for further operation.


4.2. Fire resistance

- Class F400 – fire resistance at 400°C for 120 minutes
- Class F300 – fire resistance at 300°C for 60 minutes
- Class BO, EC – without fire resistance

4.3. Versions

- unidirectional, with two-speed motor

5. DESIGNATION



6. DESIGN AND OPERATING PRINCIPLE

6.1 Design

The mcr FEN C long-range smoke exhaust fan consists of an electric motor made in an appropriate insulation class, a radial rotor and an external housing.

The motor is connected directly to the steel rotor, on which the profiled blades are placed. The angle and number of blades depend on the required thrust and efficiency of the fan. The motor bearings are resistant to high temperatures. The forced medium flows through the housing, motor and rotor – fire gases and smoky air or clean air in the case of BO or EC versions.

The fan has a junction box installed on the housing. Each type of fan has mounting brackets or frames depending on the size of the rotor.


6.2 Operation

The fan does not run in standby. The fan starts up and operates after applying the supply voltage to the terminals of the junction box of the device.

Dimensions and technical data

The basic dimensions and technical data and parameters of the fans are given below.

mcr FEN C/ FEN C/BO fan




Fan	A	B	C	D	E
mcr FEN C 50N	1230	250	870	281	963
mcr FEN C 75N	1600	300	1000	351.5	1093
mcr FEN C100N	1600	300	1000	351.5	1093

Fan	F	H	I	K	L
mcr FEN C 50N	922	600	275	13	3
mcr FEN C 75N	1052	800	250	13	4
mcr FEN C100N	1052	800	250	13	4

Fan	Thrust force	Q max	Electric power	Motor speed [rpm]	Weight
	[N]	[m3/h]	[kW]		[kg]
mcr FEN C 50N	50/13	5800	1.1/ 0.18	1420 / 710	83
mcr FEN C 75N	75/19	8280	2.2/ 0.37	1430 / 715	130
mcr FEN C100N	97/25	9200	2.2 / 0.37	1430 / 715	130

mcr FEN EC fan



Fan	A	B	C	D	E	F
mcr FEN EC 18N	956	850	873	204	573	42

Fan	Thrust force	Q max	Electric power	Motor speed [rpm]	Weight
	[N]	[m3/h]	[kW]		[kg]
mcr FEN EC 18N	18	2500	0.15x2	2500	28

Motor parameters – mcr FEN C F400 or F300

- Class H insulation, designed for continuous (S1) and emergency (S2) operation, with ball bearings, IP-55 protection, two-speed.
- Three-phase Dalhander motor 400V 4/8-pole.
- Maximum operating temperature:
- S1 mode: from -20°C to +60°C.
- S2 mode: 400°C for 2 hours.

Motor parameters – mcr FEN C/BO

- Class F insulation, S1 continuous work, ball bearings, IP-55 protection.
- Two-speed models: Dalhander three-phase motor, 4/8 poles 400V 50Hz or 400-460V 60Hz.
- Single-speed models: three-phase motor, 4 poles 230/400-460V 60Hz.
- Operating temperature range: from -20°C to +60°C.

Motor parameters – mcr FEN EC

High efficiency (IE5) and low noise motor. Speed control via 0-10V or PWM signal. Single-phase power supply 230V 50/60Hz. Motor with IP44 protection and class B insulation.

7. ASSEMBLY

The mcr FEN C long-range fan is designed for installation in rooms where air and fire gases are to be removed (FEN C F400/F300). If clean air is required, the FEN C/BO or FEN EC version is used (fans without fire resistance).


7.1. Pre-assembly inspection

Each smoke exhaust fan is inspected by the manufacturer prior to packing and shipping. Upon unpacking the delivered smoke exhaust fan, visually examine it for any damage in transport.

The motor shaft with rotor should rotate without noticeable resistance or grinding.

7.2. Location and assembly

The mcr FEN C fan is designed for horizontal installation. Before installing the fan, check the load-bearing capacity of the ceiling structure or other structural element where the device is to be suspended. The mounting frame or brackets supplied with the fan (being its integral part) are used for installation. The device is mounted to the structure using screws or mounting hangers (not supplied in the set) using the above-mentioned element.



Example of fan mounting method

- | | |
|---|------------------------------------|
| 1- Ceiling | 5 – mounting anchor (not supplied) |
| 2- mcr FEN fan | 6 – steel washers (not supplied) |
| 3- Mounting bracket (not supplied) | 7 – mounting screws (not supplied) |
| 4- Shock absorber, e.g. rubber (not supplied) | |


7.3. Electrical connections

After the fan has been properly installed, the electrical wiring should be properly connected to the device. The wires should be fed through the glands into the junction box located on the fan housing and connected in accordance with the description in the box. The motor of each fan should be connected to the grid via a circuit breaker. The protection level should be set according to the motor's rated current. Grounding should be performed in accordance with standards.

After starting the fan in the ventilation system, the current consumption should be measured and checked for compliance with the motor nameplate. The current consumed by the fan during set operation must not exceed 1.1 times the rated current.

Wiring diagram – mcr FEN C F400/F300, mcr FEN C/BO

400V DAHLANDER (Y,YY)



Wiring diagram – mcr FEN EC

Power supply 230V AC

No.	Power supply	Wire colour	Specification
1	L	brown	AC 220V / 50 Hz
2	N	blue	AC 220V / 50 Hz
3	PE	yellow-green	Grounding

0-10V signal power supply

No.	Power supply	Wire colour	Specification
1	GND	blue	Grounding
2	V sp	yellow	0-10V / PWM
3	V cc	red	DC 10V
3	FG	white	1 pulse/R

7.4. START-UP

Before start-up of the installed fan, do the following:

- check the correctness and stability of the fan mounting.
- check all seals
- check that all electrical wiring is properly and firmly connected
- check that the phase connection sequence and PE/neutral wiring is properly connected.
- check that there are no foreign objects in the fan

- check that the protective elements are attached
- after the completed inspection, switch on the fan and check the operating properties
- when switching on the fan, also check the direction of the motor rotation by verifying the correct rotation with the direction of the arrow placed on the housing

8. TRANSPORT AND STORAGE CONDITIONS

The mcr FEN C fans are placed on pallets for transport and storage. Do not topple or throw the packaging during loading and transport. Fans may be transported by any means of transport, provided they are protected against the effects of weather conditions. Fans placed on means of transport should be protected against changing their position during transport. A visual inspection of each device should be carried out after each transport operation.

Storage should take place in rooms where:

- there is no access to dust, gases, corrosive fumes and other aggressive chemical fumes that have a destructive effect on insulating elements, motor and fan construction elements,
- the maximum relative humidity does not exceed 80% at a temperature of + 20 °C,
- the ambient temperature is between – 20 °C and + 40 °C,
- there are no vibrations.

9. OHS MANUAL

Read this O&MM before fan start-up and operation. The fan does not pose a hazard provided it is carefully secured in the ventilation system and to the supporting structure. The electrical connection must be made precisely according to the attached diagram and in accordance with the instructions presented in point 7.3 of this manual. It should be performed by a person with confirmed qualifications, in accordance with applicable regulations. During use, the fan connection to the PE protective conductor should be checked. All inspection work on the fan should be performed only after disconnecting the device from the power supply.

CAUTION:

1. High-pressure and steam washers should not be used to clean the fan from deposits.
2. Leaks in connections and flexible nozzles may lead to hazards related to the release of the forced medium and should be replaced immediately.

In the event of a faulty operation of the device (excessive noise, vibrations, uneven operation), disconnect the fan from the power supply, notify the manufacturer's service or a company with the appropriate authorisation from the manufacturer to perform inspections and repairs.

10. MAINTENANCE AND SERVICING

MERCOR L&V devices should undergo periodic technical inspections and maintenance activities at least every 12 months during the entire period of use, i.e. during the warranty period, as well as after the warranty period. Inspections and maintenance should be carried out by the manufacturer or by companies authorised to service MERCOR L&V devices.

The obligation to perform regular service inspections of fire protection devices results from Article 3(3) of the Regulation of the Minister of Internal Affairs and Administration of 7 June 2010 on fire protection of buildings, other construction facilities and areas (Journal of Laws 2010, No. 109, item 719).

It is recommended to perform the following between inspections:

- Check the condition of electrical connections, paying particular attention to mechanical damage.
- Check the condition of the device body, paying particular attention to mechanical damage.
- Checking whether there are no obstacles that could affect the correct operation of the devices.

In order to perform activities falling within the scope of service inspections as well as service and warranty activities such as inspections or repairs, it is required for the User to provide physical access to the devices by, for example, dismantling thermal insulation, dismantling suspended ceilings, dismantling other installations if they prevent free access to the device, etc.

If the device is used for smoke exhaust during a fire only, it should be periodically run for approx. 10 minutes every 3 months.

For matters related to technical inspections, maintenance and service of the devices, please contact the representatives of the MERCOR L&V Service Department serwis@mercor.com.pl, phone +48 58 341 42 45 ext. 170 or fax +48 58 341 39 85 from 8:00 a.m. to 4:00 p.m. (Mon-Fri).

11. WARRANTY TERMS & CONDITIONS

1. MERCOR L&V grants a 12-month quality guarantee for the devices, counted from the date of purchase, unless the agreement provides otherwise.
2. If physical defects of the devices are revealed during the guarantee period, MERCOR L&V undertakes to remove them within no more than 21 days from the date of receipt of the written notification and delivery of proof of purchase or contract, subject to point 6.
3. MERCOR L&V reserves the right to extend the repair time in the case of complicated repairs or repairs requiring the purchase of non-standard components or spare parts.
4. The liability under the guarantee covers only defects resulting from causes inherent in the sold devices.
5. In the case of defects resulting from improper use of the devices or other reasons indicated in point 6, the Buyer / person entitled to the guarantee shall be charged with the costs of their removal.
6. The guarantee does not cover:
 - damage and failure of devices caused by misuse, interference by the user, lack of periodic technical inspections, failure to perform maintenance activities described in the "MAINTENANCE AND SERVICING" section of this document,
 - damage to equipment resulting from reasons other than those attributable to MERCOR L&V, in particular: random events such as torrential rain, flood, hurricane, inundation, lightning strike, overvoltage in the grid, explosion, hail, aircraft crash, fire, avalanche, landslide and secondary damage resulting from the above-mentioned reasons. Torrential rain is considered to be rain with a performance factor of at least 4, as determined by the Polish Institute of Meteorology and Water Management - National Research Institute (IMiGW). If it is not possible to determine the factor referred to in the preceding sentence, the actual state and extent of damage at the place of its occurrence, which will indicate the effect of torrential rain, will be taken into account. A hurricane is considered to be a wind with a speed of at least 17.5 m/s (damage is considered to have been caused by a hurricane if the effect of a hurricane has been confirmed in the immediate vicinity);
 - damage resulting from failure to immediately report a detected defect,
 - deterioration in the quality of coatings caused by their natural ageing processes,
 - defects caused by the use of abrasive or aggressive cleaning agents,
 - damage resulting from the action of aggressive external factors, in particular chemical and biological factors, or the origin of which is related to production processes and activities carried out in the facility or its immediate vicinity in which the devices were installed,
 - parts subject to natural wear and tear during use (e.g. seals), unless they have a manufacturing defect,
 - damage resulting from improper transport, unloading or storage of the device,
 - damage resulting from assembly not in accordance with the provisions of the O&MM and good construction practice,
 - devices or their parts in the event that the nameplate or guarantee seals have been torn off or damaged.
7. A guarantee claim should be sent to MERCOR L&V within 7 days from the date of discovery of the defect covered by the guarantee.
8. Guarantee claims can be submitted by phone: +48 58 341 42 45, by fax: 58/341-39-85, e-mail: reklamacje@mercor.com.pl or by sending a letter to the following address: MERCOR L&V, ul. Grzegorza z Sanoka 2, 80-408 Gdańsk.
9. The buyer/guarantee holder is obliged to properly operate the devices and to carry out periodic technical inspections and maintenance activities, in accordance with the principles described in this document in the section "MAINTENANCE AND SERVICING".
10. The guarantee expires with immediate effect in the event that:

- The Buyer/guarantee holder makes design changes on their own without prior agreement with MERCOR L&V,
 - periodic technical inspections and maintenance activities were not performed on time or were performed by unauthorised persons or service not authorised by MERCOR L&V or when the devices were used incorrectly,
 - there was any interference by unauthorised persons - outside the scope of normal operation of the devices.
11. In the cases specified in point 10, MERCOR L&V's liability under warranty is excluded.
 12. The condition for removing defects is that the reporting party provides access to the full work site, in particular ensuring: free access to the rooms in which the devices were installed and ensuring necessary revisions, dismantling of thermal insulation, dismantling of suspended ceilings, dismantling of other installations if they prevent free access to the device, etc.

In matters not covered by these warranty and guarantee conditions, the relevant provisions of the Civil Code shall apply.

FAN MEASUREMENT REPORT

FAN TYPE	
SERIAL NO.	
INSTALLATION SITE	
RATED CURRENT	

After installing the fan in its intended place and making the appropriate electrical connections, immediately measure the current consumption during steady operation.

MEASUREMENT RESULTS [A]

U1	V1	W1	U2	V2	W2

NOTES:

Full name of the person performing the measurements	Measurement date	Signature

Return this Report immediately after completion of measurements to:

Mercor Light&Vent Sp. z o.o.
Fire Ventilation Systems
Ul. Grzegorza z Sanoka 2
80-408 Gdańsk

within a maximum of 8 weeks from the date of purchase of the device (the date of purchase is the date of the VAT invoice).

SENDING THE MEASUREMENT REPORT IS THE BASIS FOR THE VALIDITY OF THE WARRANTY/GUARANTEE GIVEN FOR THE DEVICE