



NOTIFIED BODY 1396
Osloboditeľov 282, 059 35 Batizovce, Slovakia
Tel.+421 52 285 1611, www.fires.sk



Certificate of constancy of performance

1396-CPR-0022

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

STATIC SMOKE BARRIERS (SSB) mcr PROSMOKE S CE

designed to control the movement of fire effluent within construction works by forming a barrier. Assessment and verification of constancy of performance and conditions of product use are defined in document Initial type testing report of constructional product No. C1396/08/0032/5004/SC (issued by FIRES, s.r.o., Batizovce, NB1396 on 23. 07. 2008) and reports of continuous surveillances of factory production control, carried out during the validity of the certificate. The product is

placed on the market under the name or trade mark of the manufacturer

**Mercor Light&Vent sp. z o.o.
ul. Grzegorza z Sanoka 2, 80 – 408 Gdańsk, Poland**

and produced in the manufacturing plant

**Mercor Light&Vent sp. z o.o.
ul. Kwarcowa 3A, Cieplewo, 83-031 Łęgowo, Poland.**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 12101-1: 2005, EN 12101-1: 2005/A1: 2006

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 23. 07. 2008 and will remain valid as long as neither the harmonized standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

In Batizovce, on 30. 06. 2025



Representative of Notified Body

Ing. Štefan Rástocký
Head of Product Certification Body

173673

FIRES 136a/C-23/10/2024-E